

FIRE PUMP TEST REPORT

ABC Paint Company

Company

Name: **ABC Paint Company**
Address: **40 Washington Street**
City/St/Zip: **Maplewood, MD 20678**
Contact Name: **Kenney McRickles**
Phone: **410-555-1234** Ext: Fax: Cell:

Pump

Manufacturer: **Reddy Buffaloe** Label: **UL**
Model Number: **6x6 DF**
Serial Number: **845-136-DF6**
Pump Type: **Horizontal** RPM: **1750** Driver Type: **Diesel**
Rating - Churn: **0 gpm @ 60 psi**
100%: **750 gpm @ 50 psi**
150%: **1,125 gpm @ 32.5 psi**

Test

Date: **7/31/2001** Start: **12:00:00 PM** End: **12:30:00 PM**

Flows

#	Time	Disch Press	Suct Press	Flow	RPM	Amperes			Volts			Net Press	Corrected		% Flow
						A	B	C	A-B	B-C	A-C		Flow	Press	
1	12:15	118.0	62.0	0	1,783	38.0	37.0	36.0	205.0	204.0	205.0	56.0	0	54.0	0
2	12:20	111.0	60.0	378	1,776	47.0	47.0	46.0	204.0	204.0	203.0	51.0	372	50.0	50
3	12:22	100.0	54.0	756	1,767	58.0	58.0	57.0	204.0	204.0	204.0	46.0	749	45.0	100
4	12:24	84.0	47.0	1,126	1,764	64.0	65.0	63.0	204.0	205.0	203.0	37.0	1,117	36.0	149